

Article - Public Safety

§12–1101.

- (a) In this subtitle the following words have the meanings indicated.
- (b) “Carbon monoxide alarm” means a device that:
 - (1) senses carbon monoxide;
 - (2) when sensing carbon monoxide, is capable of emitting a distinct and audible sound;
 - (3) is listed and carries the listing of a nationally recognized testing laboratory approved by the Office of the State Fire Marshal; and
 - (4)
 - (i) is wired into an alternating current (AC) powerline with secondary battery backup; or
 - (ii) for a hotel or a lodging or rooming house:
 - 1. is wired into an alternating current (AC) powerline with secondary battery backup;
 - 2. is battery–powered, sealed, tamper resistant, and using a long–life battery that has a life of not less than 10 years; or
 - 3. is connected to an on–site control unit that monitors the carbon monoxide alarm remotely so that a responsible party is alerted when the device activates the alarm signal and receives its primary power from a battery or the control unit.
- (c)
 - (1) “Dwelling” means a building or part of a building that provides living or sleeping facilities for one or more individuals.
 - (2) “Dwelling” includes a one or two family dwelling, multifamily dwelling, hotel, lodging or rooming house, or dormitory.
- (d) “Hotel” has the meaning stated in § 9–201 of this article.
- (e) “Install” means to attach to the wall or ceiling of a dwelling in accordance with:
 - (1) the National Fire Protection Association (NFPA) 720 standard for the installation of carbon monoxide warning equipment in dwelling units; and
 - (2) the manufacturer’s recommendations.
- (f) “Lodging or rooming house” has the meaning stated in § 9–201 of this article.