

SB0173/914037/1

BY: Education, Health, and Environmental Affairs Committee

AMENDMENTS TO SENATE BILL 173
(First Reading File Bill)

AMENDMENT NO. 1

On page 1, in line 4, strike “the construction or remodeling of”; in line 5, strike “to conform to” and substitute “constructed or substantially remodeled in accordance with certain provisions of law to have certain carbon monoxide detectors installed in certain areas; requiring a signal from certain carbon monoxide detectors to be automatically transmitted to a certain location; requiring certain carbon monoxide detectors to be installed in conformance with”; and in line 6, strike “for commercial structures” and substitute “or those referenced by the State Fire Prevention Code”.

AMENDMENT NO. 2

On page 1, in line 21, strike the brackets; in the same line, strike the colon; and in line 22, strike “(I) ALL”.

On pages 1 and 2, strike beginning with the semicolon in line 23 on page 1 down through “STRUCTURES” in line 3 on page 2.

On page 2, after line 7, insert:

“(C) (1) (I) A BUILDING TO BE CONSTRUCTED OR SUBSTANTIALLY REMODELED UNDER THIS SECTION SHALL BE REQUIRED TO INSTALL APPROVED CARBON MONOXIDE DETECTORS IN AREAS OF NEW AND EXISTING EDUCATIONAL OCCUPANCIES WHERE FUEL FIRED EQUIPMENT IS PRESENT.

(II) A SIGNAL FROM A CARBON MONOXIDE DETECTOR INSTALLED UNDER THIS SUBSECTION SHALL BE AUTOMATICALLY TRANSMITTED

(Over)

TO AN APPROVED SUPERVISING STATION OR TO A CONSTANTLY ATTENDED ON-SITE LOCATION.

(2) THE CARBON MONOXIDE DETECTORS REQUIRED UNDER THIS SUBSECTION SHALL BE INSTALLED IN ACCORDANCE WITH THE NATIONAL FIRE PROTECTION ASSOCIATION 720: STANDARD FOR THE INSTALLATION OF CARBON MONOXIDE (CO) DETECTION AND WARNING EQUIPMENT, 2009 EDITION OR AS REFERENCED IN THE STATE FIRE PREVENTION CODE.