



HB1170/463428/1

AMENDMENTS  
PREPARED  
BY THE  
DEPT. OF LEGISLATIVE  
SERVICES

06 MAR 23  
12:14:58

BY: Delegate Adams

(To be offered in the Environment and Transportation Committee)

AMENDMENTS TO HOUSE BILL 1170

(First Reading File Bill)

AMENDMENT NO. 1

On page 1, in line 2, strike “**Public and Private**”; in the same line, strike “**Authorization**” and substitute “**Specifications and Disposal**”; and strike beginning with “authorizing” in line 3 down through “circumstances” in line 4 and substitute “establishing certain specifications for graywater systems”.

AMENDMENT NO. 2

On page 2, strike in their entirety lines 19 through 24, inclusive and substitute:

**“(B) (1) A GRAYWATER SYSTEM SHALL MEET THE SPECIFICATIONS OF THIS SUBSECTION.**

**(2) A GRAYWATER SYSTEM SHALL INCLUDE:**

**(i) A THREE-WAY VALVE INSTALLED IN A LOCATION THAT IS READILY AND EASILY ACCESSIBLE THAT DIVERTS THE GRAYWATER TO EITHER THE BUILDING SEWER OR SEPTIC SYSTEM; AND**

**(ii) A HOLDING TANK, WHICH SHALL INCLUDE:**

**1. ANCHORING TO PREVENT OVERTURNING;**

**2. A MARKING ON THE TANK INDICATING THE WATER**

**IS UNSAFE;**

3. VENTILATION;
4. AN OVERFLOW PIPE; AND
5. AN EMERGENCY PIPE THAT IS PERMANENTLY CONNECTED TO THE BUILDING SEWER.

**(3) A BACKWATER VALVE SHALL BE INSTALLED ON THE SEWER LINE TO PREVENT SEWAGE FROM ENTERING THE HOLDING TANK.**

**(4) GRAYWATER SHALL NOT BE STORED IN THE HOLDING TANK FOR MORE THAN 1 DAY.**

**(5) ALL GRAYWATER SYSTEM PIPING SHALL:**

**(I) BE WATERTIGHT; AND**

**(II) INCLUDE A MARKING ON EACH PIPE INDICATING THE WATER IS UNSAFE.”;**

and in line 25, strike “AUTHORIZED TO USE” and substitute “THAT USES”.

On page 3, in line 1, strike “UNDER SUBSECTION (B) OF THIS SECTION”.